

VIRTUAL ENERGY AUDIT UPDATE – ROUND 2

Your Power Plant on a desktop computer

Alan Werner, P.E.

VA:W


(Value Added by Werner)

COMPLEX ENVIRONMENT

FLUE TEMPERATURES

STEAM DEMAND

MECHANICAL FACTORS



FUEL MANAGEMENT

EXCESS AIR

DRIVER SELECTION

HISTORICAL FACTORS

- OPERATIONS BASED MAINLY ON INTUITION AND EXPERIENCE
- INSTRUMENTS PROVIDE THE MOST IMPORTANT DATA IN A VARIETY OF FORMATS
- ADEQUATE METHODS TO DATE
- NOTHING WRONG – BUT CAN BE IMPROVED

CONSEQUENCES

- INCOMPLETE PICTURE OF THE ENTIRE PLANT OPERATIONS
- RECORDS REFLECT ONLY A PORTION OF THE EQUIPMENT
- FORECASTING, PREDICTIONS, AND ESTIMATIONS ARE EMPIRICAL (BASED ON EXPERIENCE)

VEA


SOLUTION: The Virtual Energy Audit

- Whole plant basis – all parts working together
- Calculation with accounting leading to energy balance
- A virtual energy audit (balance) **on demand**
- Uses MS Excel – simple and direct

BASIS

ENERGY IN = ENERGY OUT*

* Product (Delivery) + Losses + Work



FUNDEMENTALS

STOICHIOMETRIC COMBUSTION

(the secret)

- Water at temp + heat \longrightarrow Steam at pressure
- BTU (British Thermal Unit): fixed unit
- Requirements from feed to output in a boiler is known and able to be calculated

FUEL

The fuel shown is natural gas (CH_4 mostly)


Solid Fuel (wood) given local data

Coal is common


Oil fuel given characteristics

Key: heating value at firing conditions

SIMPLIFIED DIAGRAM



SCHEMATIC SHEET



GOLD AND YELLOW BOXES = INPUT

OPERATOR LOG

Plant Operational Log

3/7/2008 10:35

Plant Load Total kpph kpph delivered kpph produced
 High Pressure set psig

	Boiler 1	Boiler 2	Boiler 3	Boiler 4
Load kpph	100	150	100	80
Boiler Load Factor	63%	75%	63%	67%
Plant Load Factor	23%	35%	23%	19%
Flue Gas O2 %				
Flue Gas Temp °F				
Flue Gas Flow %				
Fan Speed CFM				
Delta Pressure in H2O				
Inlet Air Temp °F				
Inlet Water Temp °F				

Water Temp °F (required input)
 Heat Recovery Inlet °F
 Heat Recovery Outlet °F Heat Recovery Op. Y or N
 Deaerator Inlet Temp °F

Number of Softeners

Make-up Pump Mode 1= all steam, 2 = all electric, 3 = steam & electric
 Feed Pump Mode 1= all steam, 2 = all electric, 3 = steam & electric

Blowdown Waste Temp °F

Plant Efficiency %

Balance

OVERALL

OVERALL PLANT OPERATION

Date **3/7/2008**
Run ID **Working**

Set Overall Plant Operation Values

Net Steam Load	430,000 Lb/hr	Delivery	404,497 Lb/hr	Proportioning Load	
15 Psi Header	133,484 Lb/hr	High Pressure	266,968 Lb/hr	HP	66% 404,497 pph
60 Psi Header	4,045 Lb/hr	High Pressure	143.8 psig	MP	1% 4,045 pph
				LP	33% 133,484 pph

Boller Set Up:

	Load Factor	
Boller # 1	100,000 23%	160,000.00 lb/hr max
Boller # 2	150,000 35%	200,000.00 lb/hr max
Boller # 3	100,000 23%	160,000.00 lb/hr max
Boller # 4	80,000 19%	120,000.00 lb/hr max
	100%	640,000.00 lb/hr max

Barometric Pressure	14.656 psia	Outside Atmospheric Temp	40 °F
Feed Water Temp	55 °F	Inside Ambient Temperature	75 °F
Deaerator Temp Out	226.99 °F		
Deaerator Temp Data	226.99 °F		

Utility Unit Costs:

Natural Gas	Set values below	Electricity	
	\$ 1.00 per therm		\$ 0.07 per kWh

Heat Recovery Used

Y

Y or N
Set Heat Recovery to N for Type A or Type D only

Plant Output Values

PRV Flow	48,170.50 Lb/hr	-
Superheat Values 60 psi Header	22.59 °F	15 psi Header 27.35 °F
Natural Gas Consumption	6,148.28 Therms/hr	
Electricity Consumption	131.6 kW/HR.	For production purposes only
Feed Water Consumption	442,030 lb/hr	882.30 GPM 1,270,505 GPD
Basic Overall Steam Load	442,030 lb/hr	Steam Losses 12,030 lb/hr
		Equiv. Loss 15,061 lb/hr

Mass Loss Index	1.0630	Factor	1.0630
-----------------	---------------	--------	---------------

Costs:

Natural Gas	\$ 6,148.28 per hour	Electricity	\$ 9.21 per hour
	\$ 147,558.82 per day (1)		\$ 221.04 per day (1)
	(1) based on uniform load		

Efficiencies

Steam	480.56 MMBTU/hr	produced	Balance	5.74%
Gas	614.83 MMBTU/hr	consumed		
Electricity	0.03 MMBTU/hr	consumed		

Steam η =	97.3%	Ratio of Steam delivered to steam used
Basic η =	78.2%	Ratio of steam produced to NG energy consumed
Plant η =	78.7%	Ratio of steam produced to output

Equivalent losses = condensation losses for steam used to heat DA



THE SOURCE



FUEL ANALYSIS

Wood Fuel Analysis

Month **12**


Sawmill Residuals		Forest Grindings		Recycle		Plywood Trim	
Ratio	54%	Ratio	23%	Ratio	10%	Ratio	13%
Moisture	56%	Moisture	55%	Moisture	38%	Moisture	4%
DFB	50% 8200	DFB	40% 8500	Urban	100% 7500	Trim	100% 8250
HFB	40% 8200	HFB	40% 8200				
Other	10% 7600	HB	20% 7200				
Composit, dry	8140		8120		7500		8250
Composit, wet	3218.125		3307.5		4218.75		7900

Net HHV **3947.4 BTU/lb** Net Moist. 47.3%

DFB Douglas Fir Bark
 HFB Hemlock Bark
 Other Cedar, et al
 HB Hardwood bark

Seasonal Moisture	Sawmill	Forest	Recycle	Plywood
January	1 60%	65%	40%	4%
February	2 60%	65%	40%	4%
March	3 60%	65%	40%	4%
April	4 56%	55%	38%	4%
May	5 53%	45%	35%	4%
June	6 49%	35%	33%	4%
July	7 45%	25%	30%	4%
August	8 45%	25%	30%	4%
September	9 45%	25%	30%	4%
October	10 49%	35%	33%	4%
November	11 53%	45%	35%	4%
December	12 56%	55%	38%	4%

Seasonal Moisture by Month



BOILER PERFORMANCE

BOILER 1			
Inputs			
Required Steam Load	129,000	lb/hr	150,000 lb/hr capacity 86.0%
Pressure	600	psig	
Steam Temperature	850.0	*F	361.1623037 *F Superheat dry bulb
Flue Gas Temperature	720.29	*F	
Excess Air	30.6%		
Residual Flue O ₂	4.45%		
Boiler Efficiency	86.0%		
Blowdown	set	1.50%	1935 lb/hr
Boiler Losses	set	2.5%	
Output			
Air Flow	89,314.66	Lb/hr	
Flue Flow	113,998.52	Lb/hr	340.41 *F
Fuel Consumption, Wet	38,033.96	Lb/hr	19.02 Tons/hr
			14,531.57 Lb/hr H ₂ O 199,112.523 BTU/hr
Steam Coil Air Heater			
Air Flow	208,860.21	lb/hr	
Inlet Temperature	51	*F	
Outlet Temperature	91.2	*F	
Approach Temperature	set value	50 *F	
Condensate Outlet	195	*F	163.0 BTU/lb
Steam Flow	5,004.86	lb/hr	194,915 BTU/hr
Static Pressure Drop	22.09	in. WG	question
Air Heater			
Gas Temp In	725.3	*F	
Gas Temp Out	340.4	*F	
Air Temp In	91.2	*F	
Air Temp Out	556.4	*F	
Air Flow	208,860.21	lb/hr	89,138.49 ACFM

FAN PERFORMANCE

Force Draft Fan

Make-up Air Gas Flow	208,860.21 lb/hr	From Actual Make-up Air Flow	400 RPM min
	89,314.66 ACFM	51 °F	1400 RPM max
Head	13.1 inch H2O		
Power Consumption	330.5 HP		83% full load ratl
Ideal Fan Power	184 HP		
Fan efficiency	56%		
Electrical:			
Ideal Electrical Load	246.22 kW	Full Load	300 HP
Electrical Efficiency	98.63%	Rated Speed	1770 RPM
Electrical Load	249.63 kW		
			851,946.76 BTU/hr

Induced Draft Fan

Flue Gas Flow	233,056.92 lb/hr	From Actual Flue Gas Flow	
	113,998.52 ACFM	340.4 °F	
	114.00 KACFM		
Head	12.2 inch H2O		
Power Consumption	307.0 HP		
Ideal Fan Power	219 HP		
Fan efficiency	71%		
Electrical:			
Ideal Electrical Load	228.70 kW	Full Load	44% full load ratl
Electrical Efficiency	99.47%	Rated Speed	700 HP
Electrical Load	229.92 kW		885 RPM
			784,659.14 BTU/hr

Distribution Fan

Air Flow	16,082.24 lb/hr	proportional from FD flow	
	6,863.64 ACFM	556.4 °F	
	6.86 KACFM		
Head	25.2 inch H2O		
Power Consumption	28.4 HP		
Ideal Fan Power	27 HP		
Fan efficiency	96%		
Electrical:			
Ideal Electrical Load	21.18 kW	Full Load	75 HP
Electrical Efficiency	99.85%	Rated Speed	1760 RPM
Electrical Load	21.21 kW		
			72,396.91 BTU/hr

Turbine-Generator



TURBINES

Turbine Generator #3

W = 3,000 MW Electrical Generation

Mechanical Efficiency 91.53% Proportion 13.1%

m1 600 psi load
 m2 vacuum pressure exhaust 87.8 °F Hood Temperature
 1099.1 BTU/lb

Computation

m1 = 27,993 lb/hr 600 psi steam

w1 = 10,238,622 BTU/hr
 Required 10,238,622 BTU/hr

Variance - BTU/hr 1
 Error % 0.00%

η Computation

m1 = 27,993

w1 = 9,370,908
 Required 10,238,622

η = 0.915250895

Turbine Generator #4

W = 9,200 MW Electrical Generation

Mechanical Efficiency 84.70% Proportion 40.2%

m1 600 psi load
 m2 265 psi extraction
 m3 vacuum pressure exhaust 102.6 °F Hood Temperature
 1105.5 BTU/lb

Computation

m1 = 200,995 lb/hr 600 psi steam

m2 = 145,000 lb/hr 265 psi extraction

w1 = 8,203,960 BTU/hr
 w2 = 18,399,013 BTU/hr
 Net 31,398,441 BTU/hr
 Required 31,398,441 BTU/hr

Variance - BTU/hr
 Error % 0.00%

Computation

m1 = 200,995 lb/hr

m2 = 145,000 lb/hr

w1 = 8,203,960 BTU/hr
 w2 = 18,399,013 BTU/hr
 Net 26,592,974 BTU/hr
 Required 31,398,441 BTU/hr

η = 0.846952047

CONDENSERS

Turbine Generator Condenser Calculation					
Cooling Pond Flow	Return	45000	GPM	@	69.02 °F
Condenser 1		18%	8100	GPM	
Condenser 2		18%	8100	GPM	
Condenser 3		18%	8100	GPM	
Condenser 4		23%	10350	GPM	
Condenser 5		23%	10350	GPM	
		100%	45000		
			Outlet to Pond		97.04 °F
Condenser 1					
Flow	Hot	72,806	lb/hr	Hood to Hot Well	
	Cold	4,058,100	lb/hr	Cooling Pond in and out	
TC1 Hood Temperature		104.2	°F	hih	1106.22 BTU/Lb
Incoming Cooling Pond Temp		69.02	°F	hic	37.06 BTU/Lb
Outlet Approach Temperature		17	°F		
Heat Exchanged		75,255,585.11	BTU/hr	Variation	#NAME?
Condenser 1 Hot Well Temp		104.589	°F	hoh	72.5731576 BTU/Lb
Outgoing Cooling Pond Temp		87.589	°F	hoc	55.6003576 BTU/Lb
Cooling Pond Temperature gain		18.57	°F		
Condenser 2					
Flow	Hot	24,832.67	lb/hr	Hood to Hot Well	
	Cold	4,058,100.00	lb/hr	Cooling Pond in and out	
TC2 Hood Temperature		96.01	°F	hih	1102.64 BTU/Lb
Incoming Cooling Pond Temp		69.02	°F	hic	37.06 BTU/Lb
Outlet Approach Temperature		6.00	°F		
Heat Exchanged		26,152,399	BTU/hr	Variation2	1,139.88
Condenser 2 Hot Well Temp		81.47	°F	hoh	49.49 BTU/Lb
Outgoing Cooling Pond Temp		75.47	°F	hoc	43.50 BTU/Lb
Cooling Pond Temperature gain		6.45	°F		
Condenser 3					
Flow	Hot	27,993.31	lb/hr	Hood to Hot Well	
	Cold	4,058,100.00	lb/hr	Cooling Pond in and out	
TC3 Hood Temperature		87.83	°F	hih	1099.13 BTU/Lb
Incoming Cooling Pond Temp		69.02	°F	hic	37.06 BTU/Lb
Outlet Approach Temperature		10.00	°F		
Heat Exchanged		29,249,830	BTU/hr	Variation3	3,143.91
Condenser 3 Hot Well Temp		86.23	°F	hoh	54.25 BTU/Lb
Outgoing Cooling Pond Temp		76.23	°F	hoc	44.26 BTU/Lb
Cooling Pond Temperature gain		7.21	°F		

THE POND



THE WORKING END



COOLING POND - NUMBERS

Cooling Pond Heat Balance

Ambient Temperature	51 °F	0	432.24
Wet Bulb Temperature	47.24 °F	0.5	76.45
Ambient Wind Speed	5 MPH	1	72.28
		2	21.61
Circulating Flow	46000 GPM	5	49.64
	23,046,000 Lb/Hr	10	1339.72
Incoming Temperature	87 °F	20	177.30
		50	-1656.40

Heat Lost in Sprays	18.1 °F		
Surface Temperature	68.89 °F	hs =	36.92 BTU/lbm
Heat Lost From Surface	49.64 BTU/hr-Sq.Ft.		
	5,886,959 BTU/Hr.		
Pond Volume	7,096,844 gallons	Heat1	2,188,003,884 BTU
		Heat2	2,182,116,925 BTU
Returning Temperature	68.82 °F	hw	36.86 BTU/lbm

Wet Bulb Calculations

Temperature	10.56 °C	
	247.86 °K	
Relative Humidity	75.2%	
Saturated Vapor Press.	1.2748 kPa	
Vapor Pressure	0.9591 kPa	
Dew Point	6.36 °C	
	43.45 °F	
Gamma	0.066890	factor
Delta	0.066199	factor
Wet bulb Temp	8.47 °C	
	47.24 °F	

MASS BALANCE

Mass Balance

Produced Steam	B1	B2	B3	Net
600 psig	129,000	109,000	219,000	457,000 pph

Delivered Steam	
10 psig	117,722 pph
265 psig	49,260 pph

Steam Uses						
	600 psi		265 psi		10 psi	
T1 Load	72,806	pph	-	pph	38,000	pph
T2 Load	24,833	pph	-	pph		
T3 Load	27,993	pph				
T4 Load	200,995	pph	145,000	pph		
T5 Load	26,025	pph				
Turbine Total	352,652					
Feed Pump, Turbine				pph		
Desuperheat Pump, Turbine				pph		
Deaerator						pph
Preheaters						pph

Losses	
Blowdown	4,235 pph
Vent	5,160 pph

PRV 10	pph
PRV 265	pph

ENERGY BALANCE

The Bottom Line

Plant Energy Balance							
In			Out				
			Energy		Mass		
Natural Gas	614.83	MMBTU/hr	150 psi Steam	319.07	MMBTU/hr	286.97	KPPH
Air	12.96	MMBTU/hr	60 psi Steam	4.83	MMBTU/hr	4.04	KPPH
Water	10.17	MMBTU/hr	15 psi Steam	158.66	MMBTU/hr	480.56	133.48 KPPH
			#1 Fan Turbine	0.55	MMBTU/hr		
			#2 Fan Turbine	0.40	MMBTU/hr		
			#3 Fan Turbine	0.28	MMBTU/hr		
			#4 Fan Turbine	0.20	MMBTU/hr		
			MU Pump	0.57	MMBTU/hr		
			FW Pump	1.49	MMBTU/hr	3.49	
			DA Heating	14.63	MMBTU/hr		
			DA vent	-	MMBTU/hr		0.00 KPPH
			Steam Trap Cond.	1.37	MMBTU/hr		
			BD	13.09	MMBTU/hr		9.15 KPPH
			Radiant Losses	9.56	MMBTU/hr	38.65	
			Flue Gas 1 & 2	17.14	MMBTU/hr		
			Flue Gas 3 & 4	61.48	MMBTU/hr	78.62	
Total	638	MMBTU/hr		601	MMBTU/hr	404.50	KPPH Delivery
						9.15	KPPH Losses
Balance	37	MMBTU/hr					
	5.74%						
			$\dot{\eta} =$	78.2%	Basic Thermal Efficiency		
			$\dot{\eta}' =$	78.7%	Overall Plant Efficiency		
			Losses	19.1%			

PAUSE

**SO, WHAT WAYS WOULD YOU SEE TO
MAKE THE VEA WORK FOR YOU?**

(There is no quiz, therefore there is no pressure.)

FEATURES

- Stand-alone program or integrated into an automated control program
- Adaptable to future changes to remain unique to a specific plant
- Operates in many modes (see later)
- Accounts for all significant equipment
 - Fans, Pumps, Deaerator-heaters, Pre-heaters, Economizers, Heat Recovery, Generators, Hot wells, Turbines/motors, chillers, pulverizers, and more...

TOOLS

- **OPTIMIZER** – FORECASTING OPERATING EFFICIENCY
- **DOCUMENTATION** – RECORDS FOR TOTAL PLANT EQUIPMENT
- **MODIFICATIONS** – RESEARCH W/ O HIGH COST
- **AUTOMATION**
- **TRAINING TOOL**
- **REPORT GENERATION**



OPERATING EFFICIENCY

Plant Operational Log 3/9/2008 10:42

Plant Load Total kpph 242.9 kpph delivered 268 kpph produced

High Pressure set 143.5 psig

	Boiler 1	Boiler 2	Boiler 3	Boiler 4
Load kpph	105	0	144	19
Boiler Load Factor	80%	0%	80%	18%
Plant Load Factor	39%	0%	54%	7%
Flue Gas O2 %				
Flue Gas Temp °F				
Flue Gas Flow %				
CFM				
Fan Speed RPM				
Delta Pressure in H2O				
Inlet Air Temp °F				
Inlet Water Temp °F				

Water Temp °F 57 (required input)

Heat Recovery Inlet °F

Heat Recovery Outlet °F Heat Recovery Op. Y Y or N

Deaerator Inlet Temp °F

Number of Softeners

Make-up Pump Mode 1= all steam, 2 = all electric, 3 = steam & electric

Feed Pump Mode 1= all steam, 2 = all electric, 3 = steam & electric

Blowdown Waste Temp °F

Plant Efficiency % 74.8%

Balance 2.22%

Case 1

$$\eta = 74.8\%$$

Plant Operational Log 3/9/2008 10:41

Plant Load Total kpph 252.8 kpph delivered 268 kpph produced

High Pressure set 143.5 psig

	Boiler 1	Boiler 2	Boiler 3	Boiler 4
Load kpph	144	0	105	19
Boiler Load Factor	80%	0%	80%	18%
Plant Load Factor	54%	0%	39%	7%
Flue Gas O2 %	2.48		2.46	4.64
Flue Gas Temp °F	807.1		680	418
Flue Gas Flow %				
CFM				
Fan Speed RPM	933		1140	815
Delta Pressure in H2O	8.3		11.6	6.6
Inlet Air Temp °F				
Inlet Water Temp °F			243.3	

Water Temp °F 57 (required input)

Heat Recovery Inlet °F 58

Heat Recovery Outlet °F 134.8 Heat Recovery Op. Y Y or N

Deaerator Inlet Temp °F 140.2

Number of Softeners 3

Make-up Pump Mode 1 1= all steam, 2 = all electric, 3 = steam & electric

Feed Pump Mode 1 1= all steam, 2 = all electric, 3 = steam & electric

Blowdown Waste Temp °F 130.2

Plant Efficiency % 79.9%

Balance 3.62%

Case 2 – documented


$$\eta = 79.9\%$$

DOCUMENTATION

Plant Operational Log		3/8/2008 10:41	
Plant Load Total	kpph	252.6	kpph delivered 268 kpph produced
High Pressure	set	143.5	psig
		Boiler 1	Boiler 2
Load	kpph	14.4	0
Boiler Load Factor		90%	0%
Plant Load Factor		54%	0%
Flue Gas O2	%	2.48	2.46
Flue Gas Temp	°F	607.1	680
Flue Gas Flow	%		418
	CFM		
Fan Speed	RPM	933	1140
Delta Pressure	in H2O	8.3	11.6
Inlet Air Temp	°F		6.6
Inlet Water Temp	°C		243.3
Water Temp	°F	57	(required input)
Heat Recovery Inlet	°F	58	
Heat Recovery Outlet	°F	134.8	Heat Recovery Op. Y Y or N
Deaerator Inlet Temp	°F	140.2	
Number of Softeners		3	
Make-up Pump Mode		1	1= all steam, 2 = all electric, 3 = steam & electric
Feed Pump Mode		1	1= all steam, 2 = all electric, 3 = steam & electric
Blowdown Waste Temp	°F	130.2	
Plant Efficiency	%	79.8%	
Balance		3.82%	

Record and document specific plant conditions with all details

AUTOMATION



SERVER



Plant Operational Log 3/7/2008 10:35

Plant Load Total kpph kpph delivered kpph produced
 High Pressure set psig

	Boiler 1	Boiler 2	Boiler 3	Boiler 4
Load kpph	100	150	100	80
Boiler Load Factor	63%	75%	63%	67%
Plant Load Factor	23%	35%	23%	19%
Flue Gas O2 %				
Flue Gas Temp °F				
Flue Gas Flow %				
CFM				
Fan Speed RPM				
Delta Pressure in H2O				
Inlet Air Temp °F				
Inlet Water Temp °F				
Water Temp °F	55	(required input)		
Heat Recovery Inlet °F				
Heat Recovery Outlet °F				
Deaerator Inlet Temp °F				
Heat Recovery Op.			Y	Y or N
Number of Softeners				
Make-up Pump Mode	1	1= all steam, 2 = all electric, 3 = steam & electric		
Feed Pump Mode	1	1= all steam, 2 = all electric, 3 = steam & electric		
Blowdown Waste Temp °F				
Plant Efficiency %	78.7%			
Balance	5.74%			

VEA

TIE-IN BETWEEN SYSTEM AUTOMATION AND VEA TO ENABLE SPECIFIC DATA RETREIVAL AND OPTIMIZATION.

TRAINING TOOL

Plant Operational Log		3/7/2008 10:35	
Plant Load Total	kpph	404.5	kpph delivered
High Pressure	set	143.5	psig
430	kpph produced		
		Boiler 1	Boiler 2
Load	kpph	100	150
Boiler Load Factor		63%	75%
Plant Load Factor		23%	35%
Flue Gas O2	%		
Flue Gas Temp	°F		
Flue Gas Flow	%		
	CFM		
Fan Speed	RPM		
Delta Pressure	in H2O		
Inlet Air Temp	°F		
Inlet Water Temp	°F		
Water Temp	°F	55	(required input)
Heat Recovery Inlet	°F		
Heat Recovery Outlet	°F		
Deaerator Inlet Temp	°F		
		Heat Recovery Op.	Y
			Y or N
Number of Softeners			
Make-up Pump Mode		1	1= all steam, 2 = all electric, 3 = steam & electric
Feed Pump Mode		1	1= all steam, 2 = all electric, 3 = steam & electric
Blowdown Waste Temp	°F		
Plant Efficiency	%	78.7%	
Balance		5.74%	

OVERALL PLANT OPERATION		Cost	270,000
Set Overall Plant Operation Values		Run ID	100000
Heat Steam Load	430,000 Lb/hr	Delivery	404,487 Lb/hr
15 Psi Header	133,800 Lb/hr	High Pressure	205,687 Lb/hr
60 Psi Header	2,040 Lb/hr	High Pressure	143.5 psig
Boiler Set-Up		Impingement	404,487 Lb/hr
		Load	265,948 Lb/hr
		MP	100
		LP	133,484 Lb/hr
		LP	33%
Boiler # 1	150,000 Lb/hr	Load Factor	100,000.00 Lb/hr max
Boiler # 2	150,000 Lb/hr		200,000.00 Lb/hr max
Boiler # 3	150,000 Lb/hr		100,000.00 Lb/hr max
Boiler # 4	50,000 Lb/hr		120,000.00 Lb/hr max
			140,000.00 Lb/hr max
Barometric Pressure	14.950 psia	100%	Outside Atmospheric Temp
			48°F
Feed Water Temp	88°F		Inside Ambient Temperature
Deaerator Temp Data	206.58°F		78°F
Deaerator Temp Data	206.58°F		
Utility Unit Costs:		set Utility Index	
Natural Gas	1.0000 \$/Btu	per Btu	Electricity
			6.00 \$/kWh
Heat Recovery Used	Y	Y or N	set Heat Recovery to N for Type A or Type D only
Plant Output Values:			
PRV Flow	48,700.00 Lb/hr		
Superheat Values:	60 psi Header	15 psi Header	213.31 °F
Natural Gas Consumption	6,349.25 Therms/hr		
Electricity Consumption	531 Lb/hr	For production purposes only	
Feed Water Consumption	245,000 Lb/hr		1,396,668 gpd
Basic Overall Steam Load	441,000 Lb/hr	Steam Losses	12,000 Lb/hr
		Blowdown Losses	13,000 Lb/hr
Mass Loss Index	1.0000	Factor	1.0000
Costs:			
Natural Gas	6,349.25 \$/hour	Electricity	3,186.00 \$/hour
	(1) Based on uniform load		(1) Based on 21.50 \$/kWh per day (1)
Efficiencies:			
Steam	250.96 Lb/MWh	produced	Balance
Gas	614.83 Lb/MWh	consumed	3.24%
Electricity	2.22 \$/MWh	consumed	
Steam η =	87.3%	Ratio of steam delivered to steam used	
Base η =	72.2%	Ratio of steam produced to kg energy consumed	
Plant η =	78.7%	Ratio of steam produced to output	
Equivalent losses = condensation losses for steam used to heat DA			

Overall

Boiler #2	
Inputs	
Required Steam Load	150,000 Lb/hr
Load Factor	75%
Pressure	143.5 psig
Steam Temperature	357.7 °F
Excess Air Used	15.8%
Excess Oxygen (Plus)	3.09%
Boiler Efficiency	85.2%
Flue Gas Temperature	561.33 °F
Blowdown	set 1.0%
Radiant Losses	set 2.0%
Output	
Air Flow	150,877.27 Lb/hr
Fuel Flow	184,450.85 Lb/hr
Fuel Consumption	9,098.35 Lb/hr
Blowdown	2,295 Lb/hr
Air Preheater	
Heating Medium	Flue Gas
Temperatures	In
Air Flow	662.30 °F
Air Inlet Temperature	60 °F
Air Outlet Temperature	400.38 °F
Out	345.60 °F
	54,746.25 ACFM
	Cp =
FD Fan Drive	
Gas Flow	54,746.25 ACFM
Speed Correction	100 RPM
Head	1120 RPM Actual
Head	4.0 inH2O
Power Consumption	56.11 kW
Ideal Fan Power	34.0 kW
Actual Efficiency	62%
Power Mode	set 1
	1 = Steam 2=Electrical
Turbine:	
Exhaust Pressure	set 18 inHg
Assumed Turbine Efficiency	96%
Energy Use	400,807 BTU/hr
Steam Flow	11,882.51 Lb/hr
Steam Power Factor, ref	215.92 Lb/kWhr
Electrical:	Note: Hypothetical
Ideal Electrical Load	0.00 MW
Electrical Efficiency	96%
Electrical Load	0.00 MW


Specific Component

Customized simulation of the specific power plant to learn how to operate and optimize quickly and without actual operation.

MODIFICATIONS

- COMPARE TWO (OR MORE) MODIFICATIONS
- DETERMINE EFFECT ON PLANT OPERATIONS – WITHOUT ACTUAL CHANGES
- CONDUCT FEASIBILITY ANALYSIS

Contact Data



V.A:W

(Value Added by Werner)

Alan Werner, P.E. Principal

aawerner@comcast.net

(425) 988-3587



www.virtenergy.com